

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

848
NNW
> 1
1.155 mi.
6101 ft.

POLE 69703
2540 BENSON AVE
BROOKLYN, NY

NY Spills S111064087
N/A

Relative:
Higher

Actual:
9 ft.

SPILLS:

Name: POLE 69703
Address: 2540 BENSON AVE
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1102195 / 2011-08-09
Facility ID: 1102195
Facility Type: ER
DER Facility ID: 404287
Site ID: 449694
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2011-05-27
Investigator: RWAUSTIN
Referred To: Not reported
Reported to Dept: 2011-05-27
CID: Not reported
Water Affected: Not reported
Spill Source: Private Dwelling
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported

Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2011-05-27
Spill Record Last Update: 2011-08-09
Spiller Name: ERT
Spiller Company: CON EDISON
Spiller Address: 2540 BENSON AVE
Spiller Company: 999
Contact Name: ERT
DEC Memo: "8/9/11 - Austin - 1 pint dry spill (stain) from pole transformer onto pavement - Con Ed contained and cleaned up the spill - See eDocs for additional information - Spill closed - end"

Remarks: "Spilled onto concrete. Cleanup pending crew arrival."

All Materials:

Site ID: 449694
Operable Unit ID: 1199899
Operable Unit: 01
Material ID: 2196298
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: .13
Units: G
Recovered: Not reported
Oxygenate: Not reported